

# Annual Environmental Report

2018



Rathangan

D0175-01

## **TABLE OF CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER**

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
  - 1.2.1 RATHANGAN WWTP
- 1.3 ELV OVERVIEW
  - 1.3.1 RATHANGAN WWTP
- 1.4 SLUDGE REMOVAL

### **2 MONITORING REPORTS SUMMARY**

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
  - 2.1.1 INFLUENT MONITORING SUMMARY - RATHANGAN WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
  - 2.2.1 EFFLUENT MONITORING SUMMARY - RATHANGAN WWTP
- 2.3 AMBIENT MONITORING SUMMARY
  - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - RATHANGAN WWTP
  - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - RATHANGAN WWTP

### **3 OPERATIONAL REPORTS SUMMARY**

- 3.1 TREATMENT EFFICIENCY REPORT
  - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - RATHANGAN WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
  - 3.4.1 SUMMARY OF INCIDENTS
  - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

### **4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION
  - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

- 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
- 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
- 4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

**5 LICENCE SPECIFIC REPORTS**

**6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS
- 6.2 DECLARATION BY IRISH WATER

**7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0175-01, Rathangan, in Kildare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

## 1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
<b>There is no Licence Specific Reports included in the AER.</b>	

## 1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant Rathangan WWTP with a Plant Capacity PE of 4000. The treatment process includes the following:

### 1.2.1 Rathangan WWTP

Treatment type	Yes / No	Details
<b>Preliminary Treatment</b>	Yes	Screening, Grit Removal
<b>Primary Treatment</b>	No	
<b>Secondary Treatment</b>	Yes	2 No. SBR
<b>Nutrient Removal</b>	Yes	Ferric Dosing
<b>Tertiary Treatment</b>	Yes	Sand Filter

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

### 1.3 ELV Overview

#### 1.3.1 Rathangan WWTP

Compliance Status	
Were all parameters compliant for Rathangan WWTP treatment plant	No
Where non compliant see Table 2.2.1 for details of parameters	

### 1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
Rathangan WWTP	Liquid Sludge	4859.3	Weight (Tonnes)	2.5	D0002 Osberstown WWTP

#### Annual Statement of Measures

There were no major capital or operational changes undertaken.

## 2 MONITORING REPORTS SUMMARY

### 2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

#### 2.1.1 Influent Monitoring Summary - Rathangan WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
<b>COD-Cr mg/l</b>	12	977	540.22
<b>Total Nitrogen mg/l</b>	5	46.9	43.46
<b>Total Phosphorus (as P) mg/l</b>	11	9.15	5.82
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	12	1724	464.78
<b>Suspended Solids mg/l</b>	12	341	174.97
<b>Hydraulic Capacity</b>		2628	836

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2.

## 2.2 Discharges from the agglomeration

### 2.2.1 Effluent Monitoring Summary - Rathangan WWTP

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Ammonia-Total (as N) mg/l	2	2.4	0	14	1	1	0.86	Fail
Total Nitrogen mg/l	0	0	0	5	0	0	3.29	N/A
True Colour PtCo Units	0	0	0	20	0	0	16.53	N/A
pH pH units	6 to 9	0	0	20	0	0	7.6	Pass
ortho-Phosphate (as P) - unspecified mg/l	1	1.2	0	13	0	0	0.47	Pass
COD-Cr mg/l	125	250	0	13	0	0	22.18	Pass
Total Phosphorus (as P) mg/l	0	0	0	11	0	0	0.82	N/A
Suspended Solids mg/l	35	87.5	0	13	0	0	3.8	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	0	13	0	0	1.33	Pass

Notes:

1– This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

#### Cause of Exceedance(s):

WWTP biological sludge issue.

#### Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence. There was 1 exceedance in relation to the Ammonia-Total (as N) parameter, which was above the Condition 2 ELV. The impact on receiving water is assessed further in Section 2.3.

## 2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

### 2.3.1 Ambient Monitoring Report Summary - Rathangan WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	266636, 219135	TPEFF1400D0175SW001	No	No	No	No	Moderate
<b>Downstream</b>	266445, 218676	TPEFF1400D0175SW001	No	Yes	No	No	Unassigned

### 2.3.2 Ambient Monitoring Parameter Summary - Rathangan WWTP

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient Monitoring Summary**



### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. Where the ambient monitoring results meet the EQS this relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

### 3 OPERATIONAL REPORTS SUMMARY

#### 3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

##### 3.1.1 Treatment Efficiency Report Summary - Rathangan WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>TN</b>	19518.56	1037.91	94.68
<b>TP</b>	1878.96	205.46	89.07
<b>COD</b>	168573.27	5175.78	96.93
<b>SS</b>	54597.1	885.69	98.38
<b>cBOD</b>	145031.38	310.19	99.79

Note: The above data is based on sample results for the number of dates reported

### 3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Rathangan WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	2400
DWF to the Treatment Plant (m <sup>3</sup> /day)	800
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	2628
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	836
Organic Capacity (PE) - As Constructed	4000
Organic Capacity (PE) - Collected Load (peak week)	3712
Organic Capacity (PE) - Remaining	288
Will the capacity be exceeded in the next three years? (Yes/No)	No

### 3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There is no Complaint data included in the AER.			

### 3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Inadequate Operational Procedures	1	No	Yes
Uncontrolled release	Other	4	No	Yes
Uncontrolled release	Inadequate Infrastructure	2	No	Yes
Non-compliance	WWTP biological sludge issue	1	No	Yes
Uncontrolled release	Plant or equipment breakdown at WWTP	1	No	Yes
Uncontrolled release	Other	1	No	Yes
Non-compliance	Plant or equipment maintenance at WWTP	1	No	Yes

#### 3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	11
Number of Incidents reported to the EPA via EDEN in 2018	11

Question	Answer
Explanation of any discrepancies between the two numbers above	N/A

### 3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP?(Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

**No Appendix Included.**

#### 4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m <sup>3</sup> )	Monitoring Status
<b>SW002 Treatment Works Storm Tank Overflow</b>	266495, 218772	Yes	Low	Meeting	43	17703	Monitored
<b>SW003 Pumping Station</b>	266627, 219143	Yes	Low	Meeting	1	646	Monitored
<b>SW004 Emergency Overflow at Inlet Works (UNLICENSED)</b>	N/A	No	Medium	Not Meeting	3	98	Monitored

#### 4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m <sup>3</sup> )?	18,497
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No

SWO Summary	
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

### 4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
Improvement works to ensure compliance with the criteria of stormwater overflows as set out in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows', 1995 SW002.	C	31/12/2015	Yes	Not Started		The improvement programme will be reviewed by IW to assess the works required to comply with the licence condition on a prioritised basis.
Improvement works to ensure compliance with the criteria of stormwater overflows as set out in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows', 1995 SW003.	C	31/12/2015	Yes	Not Started		The improvement programme will be reviewed by IW to assess the works required to comply with the licence condition on a prioritised basis.

A summary of the status of any improvements identified by under Condition 5.2 is included below.

#### 4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

#### 4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Drinking Water Abstraction Point Risk Assessment	Yes	2016	No	
Priority Substances Assessment	Yes	2016	No	

## 6 CERTIFICATION AND SIGN OFF

### 6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 19/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Acting Head of Environmental Regulation.

## 7 APPENDIX

### Appendix

#### Appendix 7.1 - Ambient Monitoring Summary

## Rathangan 2018 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	266636, 219135	RS14S010206				
Downstream Monitoring Point	266445, 218676	RS14S010220	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD (Mean) mg/l	o-Phosphate (as P) (Mean) mg/l	Ammonia (as N) (Mean) mg/l
Upstream Monitoring Point	Moderate	1.067	0.032	0.044
Downstream Monitoring Point	Unassigned*	1.200	0.049	0.071
<i>Difference</i>		<i>0.133</i>	<i>0.016</i>	<i>0.026</i>
EQS		2.600	0.075	0.140
% of EQS		5.128%	21.961%	18.797%

\*WFD status changes to 'Good' approx. 150 m downstream of the downstream sampling point

## 2018 Ambient Monitoring Data

Upstream Results							
Date		Ammonia (mg/l)	Ortho P (mg/l)	BOD (mg/l)	Total N (mg/l)	D.O (mg/l)	pH (mg/l)
4-Jan-2018	U/S	0.030	0.060	2.0	-	10.30	7.80
5-Feb-2018	U/S	0.050	0.020	1.0	-	10.80	7.65
8-Feb-2018	U/S	0.080	0.060	1.0	-	10.10	7.81
13-Feb-2018	U/S	0.060	0.050	1.0	-	10.30	7.71
6-Mar-2018	U/S	0.070	0.040	1.0	-	10.50	7.71
10-Apr-2018	U/S	0.030	0.030	1.0	0.8	9.80	7.71
1-May-2018	U/S	0.020	0.020	1.0	-	11.60	7.97
12-June-2018	U/S	0.040	0.030	1.0	-	10.10	7.37
2-July-2018	U/S	0.040	0.030	1.0	0.4	8.70	7.57
9-July-2018	U/S	0.030	0.020	1.0	-	9.80	7.49
11-July-2018	U/S	0.040	-	-	-	-	-
17-July-2018	U/S	0.030	-	-	-	-	-
8-Aug-2018	U/S	0.030	0.040	1.0	-	10.50	7.81
20-Aug-2018	U/S	0.030	0.030	1.0	-	9.40	7.63
4-Sep-2018	U/S	0.040	0.030	1.0	-	10.60	7.81
27-Sep-2018	U/S	0.080	0.030		-	-	-
1-Oct-2018	U/S	0.040	0.030		-	-	-
10-Oct-2018	U/S	0.070	0.010	1.0	-	8.97	7.23
1-Nov-2018	U/S	0.030	0.020	1.0	-	11.32	7.73
<b>Mean</b>		<b>0.044</b>	<b>0.032</b>	<b>1.067</b>	0.6	10.19	7.67
<b>95%ile</b>		<b>0.080</b>	<b>0.060</b>	<b>1.300</b>	0.8	11.40	7.86

Downstream Results							
Date		Ammonia (mg/l)	Ortho P (mg/l)	BOD (mg/l)	Total N (mg/l)	D.O (mg/l)	pH (mg/l)
4-Jan-2018	D/S	0.050	0.090	3.0	-	10.40	7.62
5-Feb-2018	D/S	0.130	0.050	1.0	-	10.90	7.60
8-Feb-2018	D/S	0.120	0.070	1.0	-	9.90	7.68
13-Feb-2018	D/S	0.080	0.070	1.0	-	10.90	7.79
6-Mar-2018	D/S	0.090	0.060	1.0	-	10.60	7.82
10-Apr-2018	D/S	0.050	0.050	2.0	-	10.60	7.70
1-May-2018	D/S	0.070	0.030	1.0	-	11.70	7.84
12-June-2018	D/S	0.060	0.050	1.0	-	10.20	7.46
2-July-2018	D/S	0.060	0.040	1.0	0.6	8.70	7.69
9-July-2018	D/S	0.050	0.030	1.0	-	9.90	7.54
11-July-2018	D/S	0.060	-	-	-	-	-
17-July-2018	D/S	0.050	-	-	-	-	-
8-Aug-2018	D/S	0.050	0.060	1.0	-	10.70	7.79
20-Aug-2018	D/S	0.060	0.040	1.0	-	9.40	7.51
4-Sep-2018	D/S	0.070	0.050	1.0	-	10.60	7.80
27-Sep-2018	D/S	0.080	0.050	-	-	-	-
1-Oct-2018	D/S	0.060	0.040	-	-	-	-
10-Oct-2018	D/S	0.080	0.020	1.0	-	8.97	7.49
1-Nov-2018	D/S	0.070	0.030	1.0	-	11.64	7.92
<b>Mean</b>		<b>0.071</b>	<b>0.049</b>	<b>1.200</b>	<b>0.6</b>	<b>10.34</b>	<b>7.68</b>
<b>95%ile</b>		<b>0.121</b>	<b>0.074</b>	<b>2.300</b>	<b>0.6</b>	<b>11.66</b>	<b>7.86</b>