

Annual Environmental Report

2019



Carnew

D0064-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CARNEW WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CARNEW WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CARNEW WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CARNEW WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO CARNEW WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0064-01, Carnew, in Wicklow in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

In February 2019, the oxidation ditch was drained down and all sludge was removed (over 500 tonnes).

In May 2019, ferric dosing was implemented at the WWTP.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CARNEW WWTP with a Plant Capacity PE of 2300, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3400D0064SW001	CARNEW WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CARNEW WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CARNEW WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	637	197.87
Total Phosphorus (as P) mg/l	4	8.54	5.61
Suspended Solids mg/l	12	916	315.73
Total Nitrogen mg/l	4	61.8	42.11
COD-Cr mg/l	12	882	531.08
Hydraulic Capacity	N/A	1032	183.96

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3400D0064SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	18.07	Pass
Suspended Solids mg/l	25	62.5	N/A	12	N/A	N/A	9.78	Pass
pH pH units	6-9	6-9	N/A	12	N/A	N/A	7.38	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	12	N/A	12	1	N/A	2.47	Pass
Ammonia-Total (as N) mg/l	0.2	0.4	N/A	12	4	4	5.82	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.1	0.2	N/A	12	N/A	N/A	0.03	Pass
Nitrate (as N) mg/l	N/A	N/A	N/A	4	N/A	N/A	15.65	
Nitrite (as N) mg/l	N/A	N/A	N/A	4	N/A	N/A	0.38	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	29.21	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.12	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

There was no ferric dosing at the plant during the first 4 months of 2019.

Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3400D0064SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	300718, 162945	RS12C760810	No	No	No	No	Good
Downstream	300693, 162961	RS12C760820	No	Yes	No	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS12C760810	0.64	RS12C760820	0.73	1.5	5.8
Ammonia-Total (as N) mg/l	RS12C760810	0.019	RS12C760820	0.057	0.065	57.7
ortho-Phosphate (as P) - unspecified mg/l	RS12C760810	0.019	RS12C760820	0.021	0.035	5.7
pH pH units	RS12C760810	7.31	RS12C760820	7.32		
Dissolved Oxygen mg/l	RS12C760810	11.38	RS12C760820	11.45		
Total Oxidised Nitrogen (as N) mg/l	RS12C760810	4.29	RS12C760820	5.3		
Suspended Solids mg/l	RS12C760810	4.25	RS12C760820	4		
Temperature °C	RS12C760810	8.95	RS12C760820	8.78		
Nitrite (as N) mg/l	RS12C760810	0.01	RS12C760820	0.01		
Conductivity 20 C µS/cm	RS12C760810	211	RS12C760820	233.25		
Dissolved Oxygen % O2	RS12C760810	97.75	RS12C760820	98.5		

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia, BOD and Ortho-P concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CARNEW WWTP

2.1.4.1 Treatment Efficiency Report - CARNEW WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
COD	35506	1208	97
TN	2843	1865	34
cBOD	13228	165	99
TP	379	7.67	98
SS	21108	654	97

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - CARNEW WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CARNEW WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	1551
DWF to the Treatment Plant (m ³ /day)	517
Current Hydraulic Loading - annual max (m ³ /day)	1032
Average Hydraulic loading to the Treatment Plant (m ³ /day)	183.96
Organic Capacity (PE) - As Constructed	2300
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	1579
Organic Capacity (PE) - Remaining	721
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CARNEW WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Industrial / Commercial Sludge	2790	Volume (m3)	34	4	No	No	No

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2019.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	1
Number of Incidents reported to the EPA via EDEN in 2019	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
SW002	300716, 162948	Yes	Low	Not Meeting	Unknown	Unknown	Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0064-SIP:02	Improvement works to ensure compliance with Condition 1.7	C	31/07/2019	Yes	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.
D0064-SIP:01	Complete improvements to comply with ELVs specified in Schedule A. Implement, in accordance with Condition 5.6.1, either (a) improvements to the existing waste water works to achieve compliance with the emission limit values specified in Schedule A.1: Primary Waste Water Discharge and Monitoring of this licence, or (b) an alternative primary discharge point, or (c) connection to another agglomeration.	C	30/06/2019	Yes	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis.

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Drinking Water Abstraction Point Risk Assessment	Yes	2015	No	
Priority Substances Assessment	Yes	2015	No	

5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT

The Drinking Water Abstraction Point Risk Assessment Report has been included in the AER 2015.

5.2 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015.

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 05/03/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included.