

# Annual Environmental Report

2019



Castleblayney

D0205-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 CASTLEBLANEY WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - CASTLEBLANEY WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - CASTLEBLANEY WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CASTLEBLANEY WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO CASTLEBLANEY WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

**7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0205-01, Castleblaney, in Monaghan in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

The following works have been completed in 2019: Provision of new storm holding facility, new preliminary treatment works, refurbished and upgraded secondary clarifiers, installation of new sludge handling facilities incl. centrifuge and PFT. Refurbishment of process pump sumps incl. M&E upgrade. New and refurbished civil and mechanical pipework site wide. Refurbishing of control building. Demolition of Muckno St. PS. Demolition of inlet works and existing storm holding tank at WWTP. Upgrade of the electrical connection, MCC room, panels. Installation of new MCCs. Installation of new instrumentation equipment site wide. Provision of new stand by generator. Site finishing and landscaping, site lighting, fencing, gate, cctv. Upgrade of 5 no. network pumping stations to provide connection to the WWTP SCADA system.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CASTLEBLANEY WWTP with a Plant Capacity PE of 12960, the treatment type is 3P - Tertiary P removal

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2400D0205SW001	CASTLEBLANEY WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l Total Phosphorus (as P) mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 CASTLEBLANEY WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CASTLEBLANEY WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	12.1	7.56
Total Nitrogen mg/l	12	87.4	52.13
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	571	241.22
COD-Cr mg/l	12	1030	562.38
Suspended Solids mg/l	12	498	165.09
Hydraulic Capacity	N/A	5022	1704

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2400D0205SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	13	N/A	N/A	32.33	Pass
Suspended Solids mg/l	35	87.5	N/A	13	N/A	N/A	11	Pass
Temperature °C	25	25	N/A	13	N/A	N/A	12.29	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	10	20	N/A	13	1	N/A	4.29	Pass
pH pH units	9	9	N/A	13	N/A	N/A	7.33	Pass
Ammonia-Total (as N) mg/l	0.5	1	N/A	13	5	4	2.87	Fail
Total Phosphorus (as P) mg/l	0.3	0.36	N/A	13	10	10	1.47	Fail
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	13	N/A	N/A	1.07	
Total Nitrogen mg/l	N/A	N/A	N/A	13	N/A	N/A	26.26	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

Refer to incident section of report.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2400D0205SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	283028, 319980	LS060009402800090	No	No	No	No	Bad
Downstream	283132, 319880	LS060009402800080	No	No	No	No	Bad

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia, BOD and Ortho-Phosphorus, concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CASTLEBLANEY WWTP

### 2.1.4.1 Treatment Efficiency Report - CASTLEBLANEY WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	3790	724	81
COD	281802	15900	94
TN	26120	12915	51
SS	82726	5411	93
cBOD	120873	2110	98

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - CASTLEBLANEY WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CASTLEBLANEY WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	8826
DWF to the Treatment Plant (m <sup>3</sup> /day)	2942
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	5022

CASTLEBLANEY WWTP	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	1704
Organic Capacity (PE) - As Constructed	12960
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	6287
Organic Capacity (PE) - Remaining	6673
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - CASTLEBLANEY WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
10	Blocked Sewer	0	10

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	EO caused by pump failure	1	No	Yes
Breach of ELV	Plant or equipment breakdown at WWTP	1	Yes	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	2
Number of Incidents reported to the EPA via EDEN in 2019	2
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
SW3	282942, 319957	Yes	Low	Meeting	Unknown	Unknown	Monitored
SW2	282879, 320154	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	282401, 320112	No	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	282841, 319528	No	Low	Not yet Assessed	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A

SWO Summary	
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	Yes

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0205-SIP:01</b>	Upgrading of Storm Water Overflows to comply with the criteria outlined in the DoEHLG "Procedures and Criteria in relation to Storm Water Overflows, 1995"	C	31/12/2015	Yes	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri
<b>D0205-SIP:02</b>	Waste water treatment plant and ancillary works	C	31/12/2015	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
D0205-IP:52	New storm holding facility, new preliminary treatment works, refurbished secondary clarifiers, installation of new sludge handling facilities incl. centrifuge and PFT. Refurbishment of process pump sumps . New and refurbished civil and mechanical pipework site wide.	Other	01/12/2019	
D0205-IP:53	Refurbishing of control building. Demolition of Muckno St. PS.	Improved Operational Control	01/12/2019	

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
<b>Drinking Water Abstraction Point Risk Assessment</b>	Yes	2013	No	
<b>Priority Substances Assessment</b>	Yes	2012	No	

### 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT

The Drinking Water Abstraction Point Risk Assessment Report has been included in the AER 2013

### 5.2 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2012



## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	Yes
List reason e.g. additional SWO identified	Additional SWO identified.
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	Yes
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 25/06/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

### Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
Upstream Monitoring Point	282870, 320196	IE_NB_06_56	■	■	■	■	Poor
Downstream Monitoring Point	283132, 319880	IE_NB_06_56	No	No	No	No	Poor

### Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (95%ile)	%EQS
BOD mg/l	282870, 320196	2.1	283132, 319880	2.2	1.5	-6.7
Ortho-Phosphate (as P) mg/l	282870, 320196	0.027	283132, 319880	0.033	0.035	-17.1
Ammonia (as N) mg/l	282870, 320196	0.046	283132, 319880	0.11	0.065	-98.5