

# Annual Environmental Report

2019



Dromcollagher

D0316-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 DROMCOLLAGHER WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - DROMCOLLAGHER WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - DROMCOLLAGHER WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR DROMCOLLAGHER WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO DROMCOLLAGHER WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SMALL STREAM RISK SCORE ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

**7 APPENDIX**

7.1 SMALL STREAM RISK SCORE ASSESSMENT

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0316-01, Dromcollagher, in Limerick in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

None. Tanks were fully cleaned out twice in 2019.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- DROMCOLLAGHER WWTP with a Plant Capacity PE of 400, the treatment type is 2 - Secondary treatment

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1900D0316SW001	DROMCOLLAGHER WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l COD-Cr mg/l Suspended Solids mg/l Total Phosphorus (as P) mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
Small Stream Risk Score Assessment	Yes

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 DROMCOLLAGHER WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - DROMCOLLAGHER WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	6.35	3.09
Suspended Solids mg/l	3	148	88.26
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	474	107.57
COD-Cr mg/l	12	657	223.09
Total Nitrogen mg/l	12	57.4	28.42
Hydraulic Capacity	N/A	462	250

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1900D0316SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	5	1	115.5	Fail
<b>Suspended Solids mg/l</b>	35	87.5	N/A	12	6	3	56.05	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	25	50	N/A	12	6	4	30.45	Fail
<b>pH pH units</b>	9	9	N/A	12	N/A	N/A	7.38	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	N/A	12	3	3	5.27	Fail
<b>Total Phosphorus (as P) mg/l</b>	1	1.2	N/A	12	9	9	2.53	Fail
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	N/A	N/A	N/A	2	N/A	N/A	1.14	
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	2	N/A	N/A	11.34	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

The WWTP is is over loaded.

### Significance of Results:

The WWTP is not compliant with the ELVs set in the WWDL. 5 parameters surpassed the ELVs set in the WWDL.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1900D0316SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	137921, 121475	RS24A020310	No	No	No	No	Bad
Downstream	137582, 121873	RS24A020400	No	No	No	No	Bad

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS24A020310	1.683	RS24A020400	3.774	1.5	139.4



<b>Ammonia-Total (as N) mg/l</b>	RS24A020310	0.067	RS24A020400	1.06	0.065	1528.2
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS24A020310	0.064	RS24A020400	0.447	0.035	1096.2
<b>Dissolved Oxygen % O2</b>	RS24A020310	96.975	RS24A020400	84.969		
<b>Temperature °C</b>	RS24A020310	10.058	RS24A020400	10.552		
<b>pH pH units</b>	RS24A020310	7.625	RS24A020400	7.719		

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia, OrthoPhosphate and BOD., concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - DROMCOLLAGHER WWTP

### 2.1.4.1 Treatment Efficiency Report - DROMCOLLAGHER WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	6335	4077	36
TP	240	184	23
TN	2205	770	65
COD	17303	8400	51
cBOD	8344	2214	73

Note: The above data is based on sample results for the number of dates reported

#### 2.1.4.2 Treatment Capacity Report Summary - DROMCOLLAGHER WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

DROMCOLLAGHER WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	257
DWF to the Treatment Plant (m <sup>3</sup> /day)	100
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	462
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	250
Organic Capacity (PE) - As Constructed	400
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	751
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - DROMCOLLAGHER WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2019.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Spillage</b>	Blocked Sewer	1	No	Yes
<b>Spillage</b>	Blocked Sewer	1	No	Yes
<b>Uncontrolled release</b>	Plant or equipment maintenance at WWTP	1	No	No

<b>Breach of ELV</b>	WWTP upgrade required to meet ELV	1	Yes	No
----------------------	-----------------------------------	---	-----	----

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
<b>Number of Incidents in 2019</b>	4
<b>Number of Incidents reported to the EPA via EDEN in 2019</b>	4
<b>Explanation of any discrepancies between the two numbers above</b>	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
<b>SW2</b>	137795, 121710	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
<b>SW3</b>	137932, 121484	Yes	Medium	Not Meeting	Unknown	Unknown	Not Monitored
<b>SW4</b>	137920, 121174	Yes	Medium	Not Meeting	Unknown	Unknown	Not Monitored
<b>TBC</b>	137932, 121484	No	Unknown	Not Meeting	Unknown	Unknown	Not Monitored

#### SWO Summary

How much sewage was discharged via SWOs in the agglomeration in the year (m3)?

Unknown

Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0316-SIP:01</b>	Additional treatment to meet the ELVs with commencement date 31/12/2021	C	31/12/2021	No	At Planning Stage	31/12/2023	
<b>D0316-SIP:02</b>	Installation of interim (package) secondary treatment plant	C	31/12/2015	Yes	At Planning Stage	31/12/2023	

A summary of the status of any improvements identified by under Condition 5.2 is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2016	No	
Small Stream Risk Score Assessment	Yes	2019	Yes	5.2

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2016

### 5.2 SMALL STREAM RISK SCORE ASSESSMENT

The Small Stream Risk Score Assessment Report is included in Appendix 7.1 - Small Stream Risk Score Assessment. A summary of the findings of this report is included below.

Parameter	Value
Condition 5 Improvement Programme Reference	Ref. 4.2 Specified Improvement Programme

<b>Does SSRS indicate discharges are posing a pollution risk?</b>	Yes
<b>Does improvement programme include any procedural and/or infrastructural works?</b>	Yes
<b>Downstream SSRS Water Quality Risk</b>	Stream At Risk
<b>SSRS Required?</b>	Yes
<b>Upstream SSRS Water Quality Risk</b>	Probably Not At Risk
<b>What is Downstream SSRS?</b>	0.2
<b>What is Upstream SSRS?</b>	8

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 09/04/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

**Appendix 7.1 - Small Stream Risk Score Assessment**