

Annual Environmental Report

2019



Castlegregory

D0461-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CASTLEGREGORY WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CASTLEGREGORY WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CASTLEGREGORY WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CASTLEGREGORY WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO CASTLEGREGORY WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SHELLFISH IMPACT ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0461-01, Castlegregory, in Kerry in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CASTLEGREGORY WWTP with a Plant Capacity PE of 300, the treatment type is 1 - Primary treatment

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1300D0461SW001	CASTLEGREGORY WWTP	Treated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CASTLEGREGORY WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CASTLEGREGORY WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	6	1580	267.27
Suspended Solids mg/l	6	812	109.57
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	1004	146.92
Hydraulic Capacity	N/A	722	393

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1300D0461SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
pH pH units	9	9	N/A	6	N/A	N/A	7.22	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	20	6	N/A	N/A	61.56	Fail
Faecal coliforms no./100mls	N/A	N/A	N/A	6	N/A	N/A	N/A	
Visual Inspection Descriptive	N/A	N/A	N/A	4	N/A	N/A	N/A	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	6	N/A	N/A	1.48	
E. Coli no./100mls	N/A	N/A	N/A	6	N/A	N/A	3590	
Enterococci (Intestinal) no./100mls	N/A	N/A	N/A	6	N/A	N/A	3525.49	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	127.14	
Suspended Solids mg/l	N/A	N/A	50	6	N/A	N/A	52.96	Pass

Ammonia-Total (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	8.77	
----------------------------------	-----	-----	-----	---	-----	-----	------	--

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

The WWTP is overloaded due to insufficient infrastructure.

Significance of Results:

The WWTP is not compliant with the ELVs set in the WWDL.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1300D0461SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	62227, 113189	TPEF1300D0461SW001	Yes	No	No	Yes	Unassigned
Downstream	63584, 112724	TPEF1300D0461SW001	No	No	No	No	Good

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CASTLEGREGORY WWTP

2.1.4.1 Treatment Efficiency Report - CASTLEGREGORY WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	15710	7593	52
TP	N/A	N/A	N/A
cBOD	21065	8827	58
COD	38322	18230	52
TN	N/A	N/A	N/A

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - CASTLEGREGORY WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CASTLEGREGORY WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	204
DWF to the Treatment Plant (m ³ /day)	68
Current Hydraulic Loading - annual max (m ³ /day)	722
Average Hydraulic loading to the Treatment Plant (m ³ /day)	393
Organic Capacity (PE) - As Constructed	300
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	606
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CASTLEGREGORY WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2019.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP operating above capacity	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	1
Number of Incidents reported to the EPA via EDEN in 2019	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
There are no Storm Water Overflows in this Agglomeration.							

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/N/A/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0461-SIP:01	Provision of sufficient primary treatment to treat all of the influent from the agglomeration	C	31/12/2015	Yes	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis
D0461-SIP:02	Remediation of the network to provide sufficient hydraulic capacity	C	31/12/2015	Yes	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2016	No	
Shellfish Impact Assessment	Yes		No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2016

5.2 SHELLFISH IMPACT ASSESSMENT

The Shellfish Impact Assessment Report has been included in the AER

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 22/04/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Station Name	Name of Receiving Water	Sampling Point Description	EDEN Code	Monitoring Location Easting/ Northing	Upstream/ Downstream	Sample Reason	Sampling Method	Sample ID No.	Sample Date	Sample Time	Laboratory Used (KCC/ S.Scientific)	Visual Inspection	pH	BOD	SS	Ortho P	Total N	NH3-N	TON	Faecal Coli	E. coli	Enterococci	Temperature (degree C)	Dissolved Oxygen mg/l	% O2	Salinity PSU	Average BOD	Average OP	Average NH3
CastlegregoryWWTP Ambient Monitoring	Cloosguire Stream	Stream	RS23C400610	E62227 N113190	Upstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	C19 - Jan 114	24/01/2019	13:55	S. Scientific Laboratory	Clear	7.1	1.2	4	0.03		0.08					9.7	9.88	86.8		1.03	0.03	0.05
CastlegregoryWWTP Ambient Monitoring	Outer Tralee Bay	Saline	CW13004114OT1003	E63584 N112724	Downstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	C19 - Jan 115	24/01/2019	13:30	S. Scientific Laboratory	Clear	7.6	1.1	4.8			0.08	0.2	1,203	79	>2,420	9.3	8.97	93.3	21.9	1.33		0.07
CastlegregoryWWTP Ambient Monitoring	Cloosguire Stream	Stream	RS23C400610	E62227 N113190	Upstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	4529 (19-01308)	06/03/2019	11:30	S. Scientific Laboratory	Clear	7.1	1.0	4	0.04		0.03					7.7	10.76	93.1				
CastlegregoryWWTP Ambient Monitoring	Outer Tralee Bay	Saline	CW13004114OT1003	E63584 N112724	Downstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	4530 (19-01308)	06/03/2019	11:05	S. Scientific Laboratory	Clear	7.5	1.2	8			0.07	0.25	3,076	4,884	496	7.5	9.04	93.3	1.9			
CastlegregoryWWTP Ambient Monitoring	Cloosguire Stream	Stream	RS23C400610	E62227 N113190	Upstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	6413(19-01853)	01/05/2019	10:20	S. Scientific Laboratory	Clear	7.0	1.0	2	0.01		0.05					10.1	8.33	73.8				
CastlegregoryWWTP Ambient Monitoring	Outer Tralee Bay	Saline	CW13004114OT1003	E63584 N112724	Downstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	6414(19-01853)	01/05/2019	09:50	S. Scientific Laboratory	Clear	7.6	1.0	2.8			0.06	0.2	8,164	5,794	318	10.8	10.69	114.8	2.5			
CastlegregoryWWTP Ambient Monitoring	Cloosguire Stream	Stream	RS23C400610	E62227 N113190	Upstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	8901(19-02733)	08/07/2019	17:00	S. Scientific Laboratory	Clear	7.1	1.0	4	0.03		0.03					15.7	5.78	57.8				
CastlegregoryWWTP Ambient Monitoring	Outer Tralee Bay	Saline	CW13004114OT1003	E63584 N112724	Downstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	8902(19-02733)	08/07/2019	16:30	S. Scientific Laboratory	Clear	8.2	1.6	4			0.127	0.02	1,112	2,064	327	21.7	10.25	136.3	26.2			
CastlegregoryWWTP Ambient Monitoring	Cloosguire Stream	Stream	RS23C400610	E62227 N113190	Upstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	11862(19-03830)	19/09/2019	14:30	S. Scientific Laboratory	Clear	7.3	1.0	4	0.02		0.06					17	9.22	95.1				
CastlegregoryWWTP Ambient Monitoring	Outer Tralee Bay	Saline	CW13004114OT1003	E63584 N112724	Downstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	11863(19-03830)	19/09/2019	14:40	S. Scientific Laboratory	Clear	8.1	1.6	2			0.035	0.02	20	122	30	21.7	10.22	135.9				
CastlegregoryWWTP Ambient Monitoring	Cloosguire Stream	Stream	RS23C400610	E62227 N113190	Upstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	14517(19-04716)	20/11/2019	14:45	S. Scientific Laboratory	Clear	7.3	1.0	4	0.03		0.04					8.5	10.75	93.8				
CastlegregoryWWTP Ambient Monitoring	Outer Tralee Bay	Saline	CW13004114OT1003	E63584 N112724	Downstream	SAMPLETYPE_COMPLIANCE	SAMPLINGMETHOD_DAY_GRAB	14518(19-04716)	20/11/2019	15:20	S. Scientific Laboratory	Clear	7.4	1.5	4			0.06	0.24	2,613	3,873	238	8.2	9.33	97.6	1.2			

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point							Unassigned	1.033	0.027	0.048
Downstream Monitoring Point			No	No	No	No	Good	1.333		0.072
<i>Difference</i>								<i>0.300</i>		<i>0.024</i>
EQS								1.500		0.065
% of EQS								20.000%		36.410%