

Annual Environmental Report

2020



Cliffoney

D0394-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CLIFFONEY WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CLIFFONEY WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CLIFFONEY WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CLIFFONEY WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO CLIFFONEY WWTP - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0394-01, Cliffoney, in Sligo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

Upgrade to existing WwTP infrastructure to meet requirements of Wastewater Discharge License

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CLIFFONEY WWTP - 2020 with a Plant Capacity PE of 800, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2700D0394SW001	CLIFFONEY WWTP - 2020	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceous) mg/l COD-Cr mg/l ortho-Phosphate (as P) - unspecified mg/l Suspended Solids mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CLIFFONEY WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CLIFFONEY WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	13	12.7	4.23
COD-Cr mg/l	13	1251	371.24
Total Nitrogen mg/l	13	86.9	35.96
Suspended Solids mg/l	13	368	129.78
BOD, 5 days with Inhibition (Carbonaceous) mg/l	13	474	147.67
Hydraulic Capacity	N/A	2097	411

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2700D0394SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	13	5	3	187.91	Fail
BOD, 5 days with Inhibition (Carbonaceous) mg/l	10	20	N/A	12	11	11	48.18	Fail
Suspended Solids mg/l	10	25	N/A	13	13	12	117.29	Fail
pH pH units	9	9	N/A	13	N/A	N/A	7.41	Pass
Ammonia-Total (as N) mg/l	0.78	1.56	N/A	13	11	11	24.01	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.72	0.86	N/A	13	8	8	1.42	Fail

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Plant / Network infrastructure not adequate

Significance of Results:

The WwTP is non compliant with the ELV's set in the Wastewater Discharge License. The impact on the receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2700D0394SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	170360, 353957	RS35C940740	No	No	No	No	Unassigned
Downstream	169861, 354487	RS35C940920	No	No	No	No	Unassigned

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in cBOD, Ammonia and Ortho-P, concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CLIFFONEY WWTP - 2020

2.1.4.1 Treatment Efficiency Report - CLIFFONEY WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	929	N/A	N/A
SS	28505	9823	66
COD	81542	15738	81
cBOD	32436	3941	88
TN	7898	N/A	N/A

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - CLIFFONEY WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CLIFFONEY WWTP - 2020	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	540
DWF to the Treatment Plant (m ³ /day)	180
Current Hydraulic Loading - annual max (m ³ /day)	2097

CLIFFONEY WWTP - 2020	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	411
Organic Capacity (PE) - As Constructed	800
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	492
Organic Capacity (PE) - Remaining	308
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CLIFFONEY WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Network Infrastructure	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
TBC	TBC, TBC	No	Unknown	Not yet Assessed	Unknown	Unknown	Unknown

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0394-SIP:01	Provide a new 800 p.e. tertiary WWTP to serve Cliffoney	C	31/12/2013	Yes	Works Completed		
D0394-SIP:02	Relocate the primary discharge point from the Cliffoney Stream to a suitable alternative receiving water (to be agreed by the Agency).	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.
D0394-SIP:03	SW001 Primary discharge Point to be discontinued	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
D0394-IP:66	Upgrade to existing WwTP infrastructure	Improved Operational Control	31/12/2022	

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2014	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2014

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 11/05/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Ambient Points **WHERE THE AMBIENT POINTS ARE NOT IN EIMS AER – PLEASE COMPLETE THE BELOW TABLE**

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
TPEFF2700D0394SW001	170,360m E, 353,957m N	RS35C940740	No	No	No	No	Unassigned
TPEFF2700D0394SW001	169,861m E, 354,487m N	RS35C940920	No	No	No	No	Unassigned

WHERE THE AMBIENT DATA IS NOT IN EDEN/EIMS – PLEASE COMPLETE THE BELOW TABLE and PLEASE ALSO INLCUDE THE MONITORING DATA

Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (95%ile)	%EQS
cBOD mg/l	RS35C940740	1.531	RS35C940920	4.525	2.6	115
Ortho-Phosphate (as P) mg/l	RS35C940740	0.027	RS35C940920	0.067	0.075	53
Ammonia (as N) mg/l	RS35C940740	0.02	RS35C940920	0.769	0.14	535

Supply Nar	Sample Date	Monitored Station	Ammonia (as N) mg/l N	BOD mg/L	Dissolved Oxygen (Site) mg/L	Dissolved Oxygen (Site) mg/L	E. Coli MPN/100ml	Enterococci No/100ml	Faecal Coliforms cfu/100ml	pH pH Units	Phosphate (Ortho/MR) mg/l P	Suspended Solids mg/L	Temperature (Site) Deg C	TON (as N) mg/l N	Total Nitrogen mg/L	Total Phosphorus-TP mg/l P
Cliffoney	30/01/2020	D0394	Downstrea	0.118	3.4	11	11	22600	21000	34000	7.5	0.017	8		1.5	0.07
Cliffoney	30/01/2020	D0394	Upstream	0.021	1.9	11	11	72	3	75	7.4	0.035	8		1	0.04
Cliffoney	25/02/2020	D0394	Downstrea	0.34	5		9	24000	3000	26000	7.3	0.093	4.8	1.4		0.13
Cliffoney	25/02/2020	D0394	Upstream	0.032	<1		10	816	66	4000	7.2	0.036	4.8	<1		0.06
Cliffoney	10/03/2020	D0394	Downstrea	0.101	1.9	9		11370	650	97000	7	0.035	8.4		<1	0.06
Cliffoney	10/03/2020	D0394	Upstream	0.039	<1	9		179	8	210	7.1	0.027	8.4		<1	0.04
Cliffoney	28/05/2020	D0394	Downstrea	4.503		10		61310	10000	44000	7.7	0.199	18.4		7.9	0.82
Cliffoney	28/05/2020	D0394	Upstream	<0.005	1.4	10		866	170	950	8.2	0.016	18.1		1.4	0.06
Cliffoney	25/06/2020	D0394	Downstrea	1.072	2.5	8		8820	280	18000	7.6	0.064	13.2		<2.5	0.15
Cliffoney	25/06/2020	D0394	Upstream	0.02	1.5	10		1733	87	3480	7.6	0.024	13.1		<2.5	0.05
Cliffoney	03/07/2020	D0394	Downstrea	0.643	2.2	10		10462	700	15000	7.6	0.061	18		2.5	0.15
Cliffoney	03/07/2020	D0394	Upstream	0.028	2.6	9		4352	980	6000	7.7	0.042	17.8		1.8	0.1
Cliffoney	10/07/2020	D0394	Downstrea	0.905	1.3	8		5570	1500	19000	7.9	0.037	12.2		<2.5	0.13
Cliffoney	10/07/2020	D0394	Upstream	0.019	<1	8		663	6	680	7.9	0.025	11.8		<2.5	0.05
Cliffoney	28/08/2020	D0394	Downstrea	0.213	1.9			1710	600	3000	7.7	0.034	13.6		<2.5	0.12
Cliffoney	28/08/2020	D0394	Upstream	0.017	1.2			426	150	440	7.7	0.023	13.5		<2.5	0.07
Cliffoney	11/09/2020	D0394	Upstream	0.01	2.9	9		10462	10	10000	7.5	0.045	13.3		3.4	0.22
Cliffoney	11/09/2020	D0394	Downstrea	0.057	4	8		1100	20	4000	7.5	0.05	13.5		3.9	0.23
Cliffoney	09/10/2020	D0394	Downstrea	0.761	23	9					7.4	0.144	9.9		<2.5	0.61
Cliffoney	09/10/2020	D0394	Upstream	0.009	1.3	10					7.6	0.023	9.8		2.8	0.06
Cliffoney	28/10/2020	D0394	Downstrea	0.069	1.8	9		9804	360	9900	8	0.035	7.4			0.07
Cliffoney	28/10/2020	D0394	Upstream	0.02	1.9	9		108	26	110	7.9	0.033	7.5			0.05
Cliffoney	06/11/2020	D0394	Downstrea	1.041	5.1	9		9208	10000	25000	7.6	0.083	9.8		<2.5	0.16
Cliffoney	06/11/2020	D0394	Upstream	0.021	1	9		52	11	53	7.6	0.012	9.6		<2.5	0.04
Cliffoney	04/12/2020	D0394	Downstrea	0.176	2.2	9		7890	380	8500	7.6	0.015	6.1		<2.5	0.07
Cliffoney	04/12/2020	D0394	Upstream	0.013	1.2	9		108	132	110	7.5	0.01	6.1		<2.5	0.04