

Annual Environmental Report

2022



Drumshanbo

D0144-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 DRUMSHANBO WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - DRUMSHANBO WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - DRUMSHANBO WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR DRUMSHANBO WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO DRUMSHANBO WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0144-01, Drumshanbo, in Leitrim in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There are no major capital or operational changes undertaken.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Drumshanbo WWTP with a Plant Capacity PE of 4000, the treatment type is 3P - Tertiary P removal .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1700D0144SW001	Drumshanbo WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 DRUMSHANBO WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - DRUMSHANBO WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
ortho-Phosphate (as P) - unspecified mg/l	12	8.53	3.34
Total Nitrogen mg/l	12	91	41
BOD, 5 days with Inhibition (Carbonaceo mg/l	12	1292	347
Ammonia-Total (as N) mg/l	12	63	28
COD-Cr mg/l	12	2702	769
pH pH units	12	7.49	6.97
Total Phosphorus (as P) mg/l	12	14	5.87
Suspended Solids mg/l	12	588	222
Hydraulic Capacity	N/A	2676	761

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1700D0144SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	19	Pass
Temperature °C	25	25	N/A	12	N/A	N/A	14	Pass
Suspended Solids mg/l	10	25	N/A	12	2	N/A	7.29	Pass
pH pH units	9	9	N/A	12	N/A	N/A	7.01	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	2	4	N/A	12	2	N/A	1.36	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.3	0.6	N/A	12	N/A	N/A	0.092	Pass
Ammonia-Total (as N) mg/l	0.21	0.42	N/A	12	3	1	0.169	Fail

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Alkalinity-total (as CaCO ₃) mg/l	N/A	N/A	N/A	1	N/A	N/A	120	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.201	
Appearance (on Sampling) Descriptive	N/A	N/A	N/A	12	N/A	N/A	N/A	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	9.52	
Odour Descriptive	N/A	N/A	N/A	12	N/A	N/A	N/A	
Conductivity @20°C µS/cm	N/A	N/A	N/A	12	N/A	N/A	565	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to Incident Section of the Report

Significance of Results:

The WWTP is non complaint with the ELV's set in the Wastewater Discharge License. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1700D0144SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	197358, 310808	RS26M800930	No	No	No	No	Moderate
Downstream	197240, 311350	RS26D050400	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS26M800930	1.75	RS26D050400	1.44	1.50	-21
Ammonia-Total (as N) mg/l	RS26M800930	0.061	RS26D050400	0.050	0.065	-17.2

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
ortho-Phosphate (as P) - unspecified mg/l	RS26M800930	0.028	RS26D050400	0.027	0.035	-0.8
Total Nitrogen mg/l	RS26M800930	0.809	RS26D050400	1.74	N/A	
pH pH units	RS26M800930	7.58	RS26D050400	7.49	N/A	
Dissolved Oxygen mg/l	RS26M800930	10	RS26D050400	10	N/A	
Suspended Solids mg/l	RS26M800930	4.96	RS26D050400	7.67	N/A	
Temperature °C	RS26M800930	13	RS26D050400	12	N/A	
Dissolved Oxygen % O2	RS26M800930	97	RS26D050400	97	N/A	

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l.

The ambient monitoring results do not meet the required EQS at the upstream monitoring location. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

A deterioration in water quality has been identified, however it is not known if it is or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are: Unknown

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - DRUMSHANBO WWTP

2.1.4.1 Treatment Efficiency Report - Drumshanbo WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	66403	2441	96
cBOD	103789	455	100
TP	1757	67	96
TN	12282	3190	74
COD	230238	6335	97

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Drumshanbo WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Drumshanbo WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	2700
DWF to the Treatment Plant (m ³ /day)	900
Current Hydraulic Loading - annual max (m ³ /day)	2676

Drumshanbo WWTP	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	761
Organic Capacity (PE) - As Constructed	4000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	1795
Organic Capacity (PE) - Remaining	2205
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - DRUMSHANBO WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2022.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Inadequate Operational Procedures / Training	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	0
Number of Incidents reported to the EPA via EDEN in 2022	0
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
SW2	197397,311345	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW3	197377,310999	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	196816,309677	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	197342,310930	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	TBC,TBC	No	TBC	Not yet Assessed	Unknown	Unknown	Monitored
TBC	TBC,TBC	No	TBC	Not yet Assessed	Unknown	Unknown	Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
SW001	197417,311236	Yes	TBC	Meeting Criteria	Unknown	Unknown	Monitored
TBC	196832,309672	No	TBC	Not yet Assessed	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
There are no Specified Improvement Programmes for this Agglomeration.							

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Drinking Water Abstraction Point Risk Assessment	Yes	2012	No
Priority Substances Assessment	Yes	2012	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 07/06/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included