

# Annual Environmental Report

2022



Glenties

D0210-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 GLENTIES WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - GLENTIES WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - GLENTIES WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR GLENTIES WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO GLENTIES WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PEARL MUSSEL REPORT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT
- 5.3 SMALL STREAM RISK SCORE ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

6.1 SUMMARY OF AER CONTENTS

**7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0210-01, Glenties, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Glenties WWTP with a Plant Capacity PE of 1600, the treatment type is 3P - Tertiary P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0210SW001	Glenties WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 GLENTIES WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - GLENTIES WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
<b>BOD, 5 days with Inhibition (Carbonaceo mg/l</b>	6	319	150
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	6	6.50	2.18
<b>Total Nitrogen mg/l</b>	6	66	31
<b>Suspended Solids mg/l</b>	6	230	85
<b>Total Phosphorus (as P) mg/l</b>	6	9.74	3.45
<b>pH pH units</b>	6	7.40	7.10
<b>Ammonia-Total (as N) mg/l</b>	6	65	26
<b>COD-Cr mg/l</b>	6	812	312
<b>Hydraulic Capacity</b>	N/A	861	260

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0600D0210SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	6	N/A	N/A	16	Pass
<b>Suspended Solids mg/l</b>	25	62.5	N/A	6	N/A	N/A	5.54	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous) mg/l</b>	25	50	N/A	6	N/A	N/A	2.15	Pass
<b>pH pH units</b>	9	9	N/A	6	N/A	N/A	7.14	Pass
<b>Ammonia-Total (as N) mg/l</b>	3	6	N/A	6	N/A	N/A	0.158	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1	2	N/A	6	N/A	N/A	0.139	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Conductivity @20°C µS/cm</b>	N/A	N/A	N/A	6	N/A	N/A	474	
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	6	N/A	N/A	0.174	
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	6	N/A	N/A	6.46	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0600D0210SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.



The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
<b>Upstream</b>	181839, 394219	RS38S010170	No	No	Yes	No	Good
<b>Downstream</b>	180444, 393117	RS38O040300	No	No	Yes	No	Good

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ortho-phosphate, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it is or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are: Unknown

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - GLENTIES WWTP

### 2.1.4.1 Treatment Efficiency Report - Glenties WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	219	10	95
cBOD	9512	124	99
TN	1983	373	81
SS	5374	320	94
COD	19818	928	95

Note: The above data is based on sample results for the number of dates reported

#### **2.1.4.2 Treatment Capacity Report Summary - Glenties WWTP**

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

<b>Glenties WWTP</b>	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	1200
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	400
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	861
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	260
<b>Organic Capacity (PE) - As Constructed</b>	1600
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	471
<b>Organic Capacity (PE) - Remaining</b>	1129
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - GLENTIES WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2022.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>There were no reportable incidents in 2022.</b>				

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	0
Number of Incidents reported to the EPA via EDEN in 2022	0
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
<b>TBC</b>	181435,394333	No	Low Significance	Meeting Criteria	Unknown	137	Monitored
<b>SW2</b>	181817,394182	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m3)?	137
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0210-SIP:02</b>	Provision of storm water holding tank at proposed main pumping station (location of existing septic tank)	C	31/12/2014	Yes	Works Completed		
<b>D0210-SIP:03</b>	SW000 located at Gortnamucklagh townland (at rear of church) to be discontinued	A	31/12/2014	Yes	Works Completed		
<b>D0210-SIP:01</b>	Provision of new Waste Water Treatment Plant and ancillary works	C	31/12/2014	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
<b>Pearl Mussel Report</b>	Yes	2013	No
<b>Priority Substances Assessment</b>	Yes	2015	No
<b>Small Stream Risk Score Assessment</b>	Yes	2016	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 03/05/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Municipal	Month	Category	Entity Name	Station	Lab Ref	Date	Ammonia (as N)	BOD	COD	Conductivity @ 20°C	Dissolved Inorganic Nitrogen DIN	DO	E coli
Dungloe	February	River Quality	Owenea	Glenties - Upstream	222500628	24-Feb-22	0.022	1	NT	152	NT	92.7	NT
Dungloe	February	River Quality	Owenea	Glenties - Downstream	222500631	24-Feb-22	0.023	1	NT	152	NT	93.1	NT
Dungloe	March	River Quality	Owenea	Glenties - Upstream	222501290	28-Mar-22	NT	NT	NT	NT	NT	NT	NT
Dungloe	March	River Quality	Owenea	Glenties - Downstream	222501291	28-Mar-22	NT	NT	NT	NT	NT	NT	NT
Dungloe	April	River Quality	Owenea	Glenties - Upstream	222501463	21-Apr-22	0.018	<1	NT	97	NT	97.6	NT
Dungloe	April	River Quality	Owenea	Glenties - Downstream	222501466	21-Apr-22	0.017	1	NT	101	NT	99	NT
Dungloe	June	River Quality	Owenea	Glenties - Upstream	222502260	15-Jun-22	0.134	1	NT	83	NT	102	NT
Dungloe	June	River Quality	Owenea	Glenties - Downstream	222502263	15-Jun-22	<0.015	1	NT	87	NT	101	NT
Dungloe	August	River Quality	Owenea	Glenties - Upstream	222503139	18-Aug-22	0.026	1	NT	164	NT	100.7	NT
Dungloe	August	River Quality	Owenea	Glenties - Downstream	222503142	18-Aug-22	0.082	1	NT	121	NT	100.5	NT
Dungloe	October	River Quality	Owenea	Glenties - Upstream	222503976	27-Oct-22	0.025	1	NT	70	NT	99	NT
Dungloe	October	River Quality	Owenea	Glenties - Downstream	222503979	27-Oct-22	0.021	1	NT	69	NT	98.9	NT

Enterococci	Faecal Coliforms	Nitrate (as N)	Nitrite (as N)	Orthophosphate	pH	Suspended Solids	Temperature	TON	Total Nitrogen	Total Phosphorus	Chlorophyll	Salinity	SSRS
NT	NT	NT	NT	0.08	6.6	<6	3.9	NT	<1	0.08	NT	NT	NT
NT	NT	NT	NT	<0.05	7	<6	5.1	NT	<1	<0.05	NT	NT	NT
NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	>6.5 - 7.25 Indeterminate Stream may be at risk.
NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	<6.5 Stream at risk.
NT	NT	NT	NT	<0.05	6.8	<6	10.9	NT	<1	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	7	<6	11	NT	<1	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	7.6	<6	13.4	NT	<1	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	7.5	<6	13.7	NT	<1	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	7.4	<6	16	NT	0.58	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	7.4	<6	15.8	NT	0.82	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	6.3	<6	12.1	NT	0.83	<0.05	NT	NT	NT
NT	NT	NT	NT	<0.05	7	<6	12.4	NT	0.62	<0.05	NT	NT	NT